

WO#: 1608D98
CLIENT: Academy for Character Education
Project:
PWS Number:
Sample Source:

Received Date: 8/31/2016 10:10:00 AM
Sampler Name: Starr Sahnnow
Matrix: Drinking Water
Sample Type:

Lab ID: 1608D98-001 **Client Sample ID:** Upstairs Water **Collection Date:** 8/30/2016 10:00:00 A

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0116	0.0200	0.00200		mg/L	9/1/2016 7:29:00 AM	SN

Lab ID: 1608D98-002 **Client Sample ID:** Down Water **Collection Date:** 8/30/2016 10:00:00 A

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.0111	0.0200	0.00200		mg/L	9/1/2016 7:29:00 AM	SN

Lab ID: 1608D98-003 **Client Sample ID:** Kitchenette Water **Collection Date:** 8/30/2016 10:00:00 A

Analyses	Method	Result	MCL	RL	Qual	Units	Date Analyzed	Analys
Lead	SM 3113 B	0.00823	0.0200	0.00200		mg/L	9/1/2016 7:29:00 AM	SN

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit