

Water Testing Results - Academy for Character Education

Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Upstairs water (no longer at site; water fountain was taken out and replaced with bottled water)	20870900-002DW	9/1/16	11.6 ppb
Downstairs water	20870900-003DF	9/1/16	11.1 ppb
Kitchenette	20870900-004KF	9/1/16	8.23 ppb

Lab results reported in mg/L. To convert from mg/L to ppb, multiply by 1,000